

## **RFQ – INSTALLATION OF ACCESS CONTROL HARDWARE Q&A #1**

- 1.** Are power supplies being provided for the maglocks.
  - a. Maglocks will be powered by Power Over Internet, so a separate power supply is not necessary.
  
- 2.** Are maglocks being installed on any custom doors like we saw during the first walk through?
  - a. There are no custom doors in the requirements.
  
- 3.** Is wire mold needed or are they going to make sure that there is a path to install the request to exit buttons.
  - a. No, wire mold is not needed.
  
- 4.** Are you providing request to exit motions, by NC code you must have 2 forms of exit when a maglock is being used. You cannot just have a button.
  - a. The NCEL is providing request to exit motion sensors and push buttons to meet the 2 forms of exit requirements. Vendor is responsible for installation.
  
- 5.** Just to confirm all home run wires will be run from controllers and wherever they will be going to.
  - a. The NCEL will provide a dedicated homerun ethernet cable from the network switch to a biscuit jack at the door/controller location. The Vendor is responsible for installing the access controller and wiring from the access controller to the biscuit jack.